

eco-INSTITUT, Schanzenstr. 6-20, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH  
Mrs. Sarah Kretschmer  
Hiltistraße 6  
86916 Kaufering

Dear Mrs. Kretschmer,

based on the evaluation of the Test Report No. 59049-A001-CS-L dated 2024-04-18, the testing results of the products **CFS-CID P** and **CFS-CID M**, commissioned by **Hilti Entwicklungsgesellschaft mbH**, comply with the requirements of

- VOC product emissions acc. to California Department of Public Health (CDPH) Standard Method v1.2-2017 (California Specification 01350 (01/2017))

These criteria meet the requirements for low-emitting **Insulation** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

| Exposure Scenario | Individual VOCs of Concern |                  | Formaldehyde |                  | TVOC        |
|-------------------|----------------------------|------------------|--------------|------------------|-------------|
|                   | Requirement                | Requirement hold | Requirement  | Requirement hold | Range       |
| School Classroom  | ½ CREL                     | yes              | ≤ 9 µg/m³    | yes              | ≤ 0.5 mg/m³ |
| Private Office    | ½ CREL                     | yes              | ≤ 9 µg/m³    | yes              | ≤ 0.5 mg/m³ |

Mass per surface area: not applicable

Cologne, 2024-04-23



Marc-Anton Dobaj, M.Sc. Crystalline Materials  
(Project manager)